

Fences

A Fence consists of posts and an associated barrier, and includes panel privacy fences, chain link fences, picket fences, barbed wire fences, corrals, and other like structures.

Considerations:

- Notwithstanding anything herein, Fences within the Right of Way or 1.5 metres of the Pipeline where no Right of Way exists may be removed by SaskEnergy at the Grantee or owner's expense if access is required to construct, inspect, maintain, alter, replace or repair the Pipeline, or if a safety concern arises.
- Fence posts should be placed in locations greater than 0.6 metres from natural gas Pipelines to avoid the legislated requirement for hydro-vac excavation, or hand digging.

Allowed:

- Fence panels less than 2.5 metres in height may extend over Pipelines.
- Fence posts may be placed with a powered auger or post pounder if the offset is more than 0.6 metres from the Pipeline.
- Fence posts may be placed at a 0.3 metres minimum offset from the Pipeline if post holes are hydro-vac excavated or hand dug.
- Mechanical Excavation or post pounding is allowed within 0.6 metres from the Pipeline, only if the exact pipe location is visually verified by hand digging, or hydro-vac excavation.

Prohibited:

- Any Fence not meeting the "allowed" criteria above, including:
 - Fences greater than 2.5 metres in height over Pipeline; and
 - Fence post within .3 metres of Pipeline.

