



December 16, 2020

Village of Debden  
P.O. Box 400  
DEBDEN, SK  
S0J 0S0

Dear Administration and Council:

This letter is to advise you that a Precautionary Drinking Water Advisory (PDWA) has been placed on **the residents located on 3<sup>rd</sup> Avenue West from 1<sup>st</sup> Street to Mainstreet in the Village of Debden effective December 16, 2020 and until further notice.**

The Water Security Agencies protocol is to place systems that experience depressurization on a PDWA. This Precautionary Drinking Water Advisory remains in effect until the safety of the Village's water supply in the affected distribution system can be ensured at all times. Therefore, I ask that the administration notify all users of the effected municipal drinking water distribution system of the conditions in the attached Precautionary Drinking Water Advisory.

This advisory can be rescinded following:

- 1) Repairs are complete.
- 2) The system is disinfected and flushed to applicable standards.
- 3) The receipt of two (2) consecutive sets of one (1) bacteriological samples (marked as 'other') which show negative results for bacteriological growth in the final treated potable water being supplied. The two sets of samples should be taken at least 24 hours apart from representative areas in the distribution system.

Thank you for your cooperation in this regard. For further information please do not hesitate to contact the undersigned at 306-441-5774 or Kerry Desjarlais at 306-961-8400.

Sincerely,

A handwritten signature in black ink, appearing to be "Kris Dushire", written over a circular stamp or mark.

Kris Dushire  
Environment Officer  
Drinking Water and Wastewater Management Division  
Water Security Agency

cc. Barry Wright – Manager WSA  
Kerry Desjarlais – WSA EPO  
Saskatchewan Health Authority –Prince Albert Office